


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Director: Dr. Thomas-Benjamin Seiler

Legal Entity: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



Hygiene-Institut · PO Box 10 12 55 · DE 45812 Gelsenkirchen · Germany

Address:
Rotthäuser Str. 21, DE 45879 Gelsenkirchen

Switchboard +49 (0)209 9242-0
Telefax +49 (0)209 9242-222
Internet www.hyg.de

Our reference: W-348009-21-JRoll
Contact person: Dipl.-Ing. (FH) S. Horn

Gelsenkirchen, 20.08.2021

Certificate

hygiene-conformity check to the design requirements of selected regulations

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthäuser Straße 21
45879 Gelsenkirchen

Test object: air handling unit type WiVent-B

Manufacturer: Wildeboer Bauteile GmbH
Marker Weg 11
26826 Weener

Basis of the examination: ✓ VDI 6022, sheet 1 (01/2018) ✓ VDI 3803, sheet 2 (06/2019)
✓ ÖNORM H 6021 (08/2016) ✓ SWKI VA104-01 (01/2019)

Validity period: 5 years 08/2021 – 08/2026

Test report: W-348009-21-JRoll



In conclusion it can be stated that the examined air handling unit type WiVent-B, as specified in the test report W-348009-21-JRoll, is in compliance with the above mentioned regulations.

Within the framework of the hygiene conformity testing, the hygienically relevant constructive requirements were tested in accordance with the afore mentioned regulations. Further test perimeters: microbiological material testing, testing of the cleaning and disinfectant resistance, testing of the instructions for use and the regular, at least annual, hygienic production monitoring of the components by the Hygiene-Institut des Ruhrgebiets. The test was conducted with regard to hygienic aspects of the specified regulations only. However, the hygiene conformity testing does not include toxicological and sensory testing of the materials.

(Dipl.-Ing. (FH) S. Horn)
Head of the Department hygienic building technology

(J. Rolle B. Eng.)
clerk of the Department hygienic building technology

issued 20.08.2021, Gelsenkirchen

Within the framework of the conformity check the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.